



Certificate of Compliance

Certificate: 2011806

Master Contract: 242437

Project: 2155089

Date Issued: 2009/07/24

Issued to: **Pietro Fiorentini**

Via Enrico Fermi 8/10
Areugnano, Vicenza 36057
Italy

Attention: Gianfranco Defeo

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Richard Clark

Authorized by: Renzo Pupulin, C.E.T., Product Group Manager

PRODUCTS

CLASS 3331 85 - REGULATORS (GAS) - Line Pressure-Certified to U.S. Standards

CLASS 3331 02 - REGULATORS (GAS) - Gas Appliance Pressure

CLASS 3331 82 - REGULATORS (GAS) - Gas Appliance Pressure-Certified to U.S. Standards

CLASS 3331 05 - REGULATORS (GAS) - Line Pressure

Regulator Class II with maximum outlet pressure of 2 PSIG

Regulator Class I with maximum outlet pressure of 1/2 PSIG

Appliance regulators are approved for pilot flow conditions



CSA INTERNATIONAL

Certificate: 2011806

Master Contract: 242437

Project: 2155089

Date Issued: 2009/07/24

Model	Size	Maximum Inlet	Maximum Inlet
		(Class I, Class II & Appliance)	(Class I, Class II & Appliance)
Number	Inches	Pressure (PSIG)	Pressure (PSIG)
30051	½	5	2
30052	¾	5	2
30053	1	5	2
30150	½	5	2
30151	¾	5	2
30152	1	5	2
30153	1 ¼	5	2
30154	1 ½	5	2
30155	2	5	2
30157/F	3	5	2
30158/F	4	5	2

Models with Slam Shut OPCO

32051	½	5
32052	¾	5
32053	1	5

Models with OPD Regulator

30051DC	1/2	5
30052DC	3/4	5



Certificate: 2011806

Master Contract: 242437

Project: 2155089

Date Issued: 2009/07/24

30053DC	1	5
30150DC	1/2	5
30151DC	3/4	5
30152DC	1	5
30153DC	1 1/4	5
30154DC	1 1/2	5
30155DC	2	5
30157DC/F	3	5
30158DC/F	4	5

APPLICABLE REQUIREMENTS

ANSI Z21.80a / CSA 6.22a-2005 Line Pressure Regulators

ANSI Z21.18 / CSA 6.3-2007 Gas Appliance Pressure Regulators